

ERC Testing Ltd.

Unit A8(3), Pennington Court, Moss Industrial Estate, Leigh Lancashire WN7 3PT

Tel: 01942 603927. Company Registration No. 9819101



REPORT NUMBER:	901153
CLIENT:	BAKO OKNA
PRODUCT:	VERTICAL SLIDING SASH WINDOW (SPIRAL BALANCE)
SIM-SOFTWARE:	WINISO (VERSION 2.8.1)
MATERIAL:	SOFTWOOD
GLASS CONFIGURE:	4CLEAR/16/4PLANITHERM ONE, SWISSPACER ADVANCE SPACER
SEALANT:	HOTMELT BUTYLE
CENTRE PANE U-VALUE (U_G):	1.042 W/M2K
SOLAR FACTOR (g):	0.52
THERMAL TRANSMITTANCE (U-VALUE):	1.2 W/M2K
ENERGY INDEX:	N/A
ENERGY RATING:	N/A

Approved testing body, registered with UKAS under accreditation number **23361**, and is a registered company at the Ministry of Housing, Communities and Local Government (MHCLG) under number **8544**.

Authorised by:-

Signature

A handwritten signature in black ink, appearing to read 'Fradley', is written over a light blue background.

Peter Fradley
ERC Testing Ltd
Date:

Version: V0
Date: 14th February 2025